



ORIGINAL

Ref. No.: 1045/ 05/center

Date : 18 September, 2005

INT'L CENTER FOR ANALYSIS & TESTING

Compression Test Report

Type of compression M / C: ADR 2000 standard Sr. No. : 1708- 3 - 5071

Client : بروكيم

Casted by : Comibassal

Type of Curing : By Client

Date of Receiving : 15. 9 .2005

Date of Breaking : 17.9.2005

Cube Dimensions : 7.1 x 7.1 x 7.1Cm

S.A. : 50.41 Cm²

Cube No.	Date of Casting	Cube Age	Type of Sampling	Wt (g)	Load (KN)	Stress KN / Cm ²
1	10.9.2005	7	مادة كيم سيل F	750	126	2.5
2	10.9.2005	7	"	750	154	3.0
3	10.9.2005	7	"	750	156	3.0

Civil Engineer

Director



For
Eng . / Said Abd El Gawad



H-

٤٠ ش صفيية زغلول ص . ب . ١٥٧ الاسكندرية - مصر ت : ٤٨٧٠٥٧٢ - ٤٨٦١٦٩١ فاكس : ٤٨٦٩٧٩٨ - ٤٨٧٠٦٦٥

٩ ش الحاتمى - ميناء البصل - اسكندرية ت : ٢٩٣٣٨٧٢ - ٢٩٠٧٦١٧ فاكس : ٢٩٢٠٣٢٧

40 Safia Zaghoul St. - P.O.Box 157 Alexandria - Egypt Tel.: 4870573 - 4861691 Fax 4869798 - 4870665

9 El Hatemy St. Alexandria. Tel. 3933873 -3907617 . Fax : 3920327